

Tillamook School District Radon Testing Results

The EPA's recommended action level for radon is 4 pCi/L and will require mitigation by the district, followed by retesting.

14 Spike tests were conducted to ensure the integrity of the testing process and all spike tests passed satisfactorily.

| Site Name | Building Name | Room Description (per floor plan) | Kit serial # | Date Sampled | Type of test | Results (pCi/L) |
|-----------------|-----------------|--------------------------------------|--------------|--------------|--------------|--------------------|
| Wilson School | Wilson School | Room 7 | 4156191 | 6/3/2020 | Detector kit | 0.5 |
| Wilson School | Wilson School | Room Office | 4155851 | 6/3/2020 | Detector kit | 0.7 |
| Wilson School | Wilson School | Room Principal | 4156192 | 6/3/2020 | Detector kit | 0.7 |
| Wilson School | Wilson School | Room 8 | 4156193 | 6/3/2020 | Detector kit | 0.6 |
| Wilson School | Wilson School | Room 9 | 4155915 | 6/3/2020 | Detector kit | 0.5 |
| Wilson School | Wilson School | Room 10 | 4156194 | 6/3/2020 | Detector kit | 0.5 |
| Wilson School | Wilson School | Room 11 | 4155913 | 6/3/2020 | Detector kit | <0.3 |
| Wilson School | Wilson School | Room 11 Duplicate | 4155912 | 6/3/2020 | Duplicate | 0.5 |
| Wilson School | Wilson School | Room 12 | 4155911 | 6/3/2020 | Detector kit | 0.4 |
| Wilson School | Wilson School | Floor 1 Room Office | 4155852 | 6/3/2020 | Detector kit | 0.6 |
| Wilson School | Wilson School | First Floor Room Health | 4155853 | 6/3/2020 | Detector kit | 0.4 |
| Wilson School | Wilson School | First Floor Room Library | 4155914 | 6/3/2020 | Detector kit | 0.9 |
| Wilson School | Wilson School | First Floor Room Adim | 4156195 | 6/3/2020 | Detector kit | 0.7 |
| Wilson School | Wilson School | First Floor Classroom 102 | 4156197 | 6/3/2020 | Detector kit | <0.3 |
| Wilson School | Wilson School | First Floor Room Corner Office | 4156196 | 6/3/2020 | Detector kit | <0.3 |
| Wilson School | Wilson School | First Floor Classroom 101 | 4156198 | 6/3/2020 | Detector kit | <0.3 |
| Wilson School | Wilson School | First Floor Classroom 100 | 4156200 | 6/3/2020 | Detector kit | 0.5 |
| Wilson School | Wilson School | First Floor Classroom 113 | 4155856 | 6/3/2020 | Detector kit | <0.3 |
| Wilson School | Wilson School | First Floor Room Gym | 4156184 | 6/3/2020 | Detector kit | 1.1 |
| Wilson School | Wilson School | First Floor Room Gym | 4155854 | 6/3/2020 | Detector kit | 1.4 |
| Wilson School | Wilson School | First Floor Room 112 | 4155859 | 6/3/2020 | Detector kit | 0.5 |
| Wilson School | Wilson School | First Floor Room 111 | 4155860 | 6/3/2020 | Detector kit | 0.6 |
| Wilson School | Wilson School | First Floor Room Kitchen | 4155951 | 6/3/2020 | Detector kit | 0.8 |
| Wilson School | Wilson School | First Floor Room Cafeteria | 4155858 | 6/3/2020 | Detector kit | 0.9 |
| Wilson School | Wilson School | First Floor Room Cafeteria | 4155952 | 6/3/2020 | Detector kit | 1.0 |
| Wilson School | Wilson School | First Floor Room Cafeteria | 4155957 | 6/3/2020 | Detector kit | 0.9 |
| Wilson School | Wilson School | First Floor Room Cafeteria Dup | 4155958 | 6/3/2020 | Duplicate | 0.8 |
| Wilson School | Wilson School | First Floor Room Stage | 4155955 | 6/3/2020 | Detector kit | 1.0 |
| Wilson School | Wilson School | First Floor Room Gym | 4155956 | 6/3/2020 | Detector kit | 1.0 |
| Wilson School | Wilson School | First Floor Room Gym | 4155855 | 6/3/2020 | Detector kit | 0.8 |
| East Elementary | East Elementary | First Floor Staff Room 12 | 4156313 | 6/3/2020 | Detector kit | 0.6 |
| East Elementary | East Elementary | First Floor Room Office Main | 4155933 | 6/3/2020 | Detector kit | <0.3 |
| East Elementary | East Elementary | First Floor Room Front Office 1 | 4156152 | 6/3/2020 | Detector kit | 0.5 |
| East Elementary | East Elementary | First Floor Classroom 18 | 4156312 | 6/3/2020 | Detector kit | 0.6 |
| East Elementary | East Elementary | First Floor Room 17 | 4155972 | 6/3/2020 | Detector kit | <0.3 |
| East Elementary | East Elementary | First Floor Room 20B | 4156315 | 6/3/2020 | Detector kit | 0.6 |
| East Elementary | East Elementary | First Floor Room 20A | 4155872 | 6/3/2020 | Detector kit | 0.8 |
| East Elementary | East Elementary | First Floor Room 22 | 4155936 | 6/3/2020 | Detector kit | 0.5 |
| East Elementary | East Elementary | First Floor Room 24 | 4156252 | 6/3/2020 | Detector kit | 0.7 |
| East Elementary | East Elementary | First Floor Room 26 | 4155935 | 6/3/2020 | Detector kit | 0.4 |
| East Elementary | East Elementary | First Floor Room 28 | 4155934 | 6/3/2020 | Detector kit | 0.4 |
| East Elementary | East Elementary | First Floor Room 30 | 4155937 | 6/3/2020 | Detector kit | <0.3 |
| East Elementary | East Elementary | First Floor Room 31B | 4156319 | 6/3/2020 | Detector kit | 0.4 |
| East Elementary | East Elementary | First Floor Room 31A | 4156316 | 6/3/2020 | Detector kit | <0.3 |
| East Elementary | East Elementary | First Floor Room 29 | 4156317 | 6/3/2020 | Detector kit | <0.3 |
| East Elementary | East Elementary | First Floor Room 27 | 4156318 | 6/3/2020 | Detector kit | <0.3 |
| East Elementary | East Elementary | First Floor Room 23 | 4156257 | 6/3/2020 | Detector kit | <0.3 |
| East Elementary | East Elementary | First Floor Room Desk | 4156253 | 6/3/2020 | Detector kit | 0.4 |
| East Elementary | East Elementary | First Floor Room 25 | 4156256 | 6/3/2020 | Detector kit | 0.5 |
| East Elementary | East Elementary | First Floor Room 21 | 4156254 | 6/3/2020 | Detector kit | 0.4 |
| East Elementary | East Elementary | Room 19 | 4156258 | 6/3/2020 | Detector kit | 0.7 |
| East Elementary | East Elementary | Room 15 | 4156259 | 6/3/2020 | Detector kit | <0.3 |
| East Elementary | East Elementary | Room 26 Duplicate | 4155873 | 6/3/2020 | Duplicate | <0.3 |
| East Elementary | East Elementary | Room 25 Duplicate | 4155874 | 6/3/2020 | Duplicate | <0.3 |
| East Elementary | East Elementary | Room 13D | 4155876 | 6/3/2020 | Detector kit | 0.6 |
| East Elementary | East Elementary | Room 13C | 4156260 | 6/3/2020 | Detector kit | 0.4 |
| East Elementary | East Elementary | Room 13B | 4155877 | 6/3/2020 | Detector kit | 0.5 |
| East Elementary | East Elementary | Room 13A | 4155878 | 6/3/2020 | Detector kit | <0.3 |
| East Elementary | East Elementary | Room 8 | 4156144 | 6/3/2020 | Detector kit | 0.4 |
| East Elementary | East Elementary | Room Multipurpose North | 4155880 | 6/3/2020 | Detector kit | 0.7 |
| East Elementary | East Elementary | Room Multipurpose Middle | 4155879 | 6/3/2020 | Detector kit | <0.3 |
| East Elementary | East Elementary | Room Multipurpose South | 4156154 | 6/3/2020 | Detector kit | 0.8 |
| East Elementary | East Elementary | Room Multipurpose North Dup | 4155875 | 6/3/2020 | Duplicate | 0.5 |
| East Elementary | East Elementary | Room Kitchen | 4156320 | 6/3/2020 | Detector kit | 0.4 |
| East Elementary | East Elementary | Room Cafeteria North | 4156155 | 6/3/2020 | Detector kit | 0.9 |
| East Elementary | East Elementary | Room Cafeteria South | 4156156 | 6/3/2020 | Detector kit | 0.8 |
| East Elementary | East Elementary | Room 7 | 4155939 | 6/3/2020 | Detector kit | 0.4 |
| East Elementary | East Elementary | Room 5 | 4156157 | 6/3/2020 | Detector kit | 0.4 |
| East Elementary | East Elementary | Room 3 | 4156158 | 6/3/2020 | Detector kit | 0.6 |
| East Elementary | East Elementary | Room 3 Field Blank | 4156159 | 6/3/2020 | Detector kit | <0.3 |

Tillamook School District Radon Testing Results

The EPA's recommended action level for radon is 4 pCi/L and will require mitigation by the district, followed by retesting.

14 Spike tests were conducted to ensure the integrity of the testing process and all spike tests passed satisfactorily.

| Site Name | Building Name | Room Description (per floor plan) | Kit serial # | Date Sampled | Type of test | Results (pCi/L) |
|-----------------------|-----------------------|---|--------------|--------------|--------------|--------------------|
| East Elementary | East Elementary | Room 1 | 4155973 | 6/3/2020 | Detector kit | 0.6 |
| East Elementary | East Elementary | Room Gym Central | 4155938 | 6/3/2020 | Detector kit | 0.7 |
| East Elementary | East Elementary | Room Gym Central Duplicate | 4156160 | 6/3/2020 | Duplicate | 0.6 |
| East Elementary | East Elementary | Room Gym South | 4156143 | 6/3/2020 | Detector kit | 0.9 |
| East Elementary | East Elementary | Room Gym North | 4156145 | 6/3/2020 | Detector kit | 0.6 |
| East Elementary | East Elementary | Room 2 | 4156146 | 6/3/2020 | Detector kit | 0.9 |
| East Elementary | East Elementary | Room 4 | 4156149 | 6/3/2020 | Detector kit | 0.4 |
| East Elementary | East Elementary | Room 6 | 4156147 | 6/3/2020 | Detector kit | <0.3 |
| Liberty Elementary | Liberty Elementary | First Floor Room Office | 4155857 | 6/3/2020 | Detector kit | <0.3 |
| Liberty Elementary | Liberty Elementary | First Floor Classroom 2 | 4155953 | 6/3/2020 | Detector kit | <0.3 |
| Liberty Elementary | Liberty Elementary | First Floor Room Office 1 | 4156190 | 6/3/2020 | Detector kit | <0.3 |
| Liberty Elementary | Liberty Elementary | First Floor Classroom 9 | 4156189 | 6/3/2020 | Detector kit | <0.3 |
| Liberty Elementary | Liberty Elementary | First Floor Room Principal | 4156188 | 6/3/2020 | Detector kit | <0.3 |
| Liberty Elementary | Liberty Elementary | First Floor Room 24 | 4156181 | 6/3/2020 | Detector kit | <0.3 |
| Liberty Elementary | Liberty Elementary | First Floor Room 22 | 4156182 | 6/3/2020 | Detector kit | <0.3 |
| Liberty Elementary | Liberty Elementary | First Floor Room 21 | 4156187 | 6/3/2020 | Detector kit | <0.3 |
| Liberty Elementary | Liberty Elementary | First Floor Room 21 Duplicate | 4156186 | 6/3/2020 | Duplicate | <0.3 |
| Liberty Elementary | Liberty Elementary | First Floor Room 26 | 4156185 | 6/3/2020 | Detector kit | 0.5 |
| Liberty Elementary | Liberty Elementary | First Floor Room Media Center | 4155960 | 6/3/2020 | Detector kit | <0.3 |
| Liberty Elementary | Liberty Elementary | First Floor Room Media Center | 4155959 | 6/3/2020 | Detector kit | <0.3 |
| Liberty Elementary | Liberty Elementary | First Floor Classroom 3 | 4156183 | 6/3/2020 | Detector kit | <0.3 |
| Liberty Elementary | Liberty Elementary | First Floor Classroom 25 | 4155867 | 6/3/2020 | Detector kit | <0.3 |
| Liberty Elementary | Liberty Elementary | First Floor Room 4 | 4155868 | 6/3/2020 | Detector kit | <0.3 |
| Liberty Elementary | Liberty Elementary | First Floor Room 5 | 4155865 | 6/3/2020 | Detector kit | <0.3 |
| Liberty Elementary | Liberty Elementary | First Floor Room 6 | 4155866 | 6/3/2020 | Detector kit | 0.4 |
| Liberty Elementary | Liberty Elementary | First Floor Room 7 | 4155869 | 6/3/2020 | Detector kit | <0.3 |
| Liberty Elementary | Liberty Elementary | First Floor Classroom 8 | 4155862 | 6/3/2020 | Detector kit | <0.3 |
| Liberty Elementary | Liberty Elementary | First Floor Classroom 8 Duplicate | 4155861 | 6/3/2020 | Duplicate | <0.3 |
| Liberty Elementary | Liberty Elementary | First Floor Classroom 10 | 4155863 | 6/3/2020 | Detector kit | <0.3 |
| Liberty Elementary | Liberty Elementary | First Floor Classroom 13 | 4155870 | 6/3/2020 | Detector kit | <0.3 |
| Liberty Elementary | Liberty Elementary | First Floor Classroom 14 | 4155904 | 6/3/2020 | Detector kit | <0.3 |
| Liberty Elementary | Liberty Elementary | First Floor Classroom 15 | 4155905 | 6/3/2020 | Detector kit | <0.3 |
| Liberty Elementary | Liberty Elementary | First Floor Modular Room | 4155907 | 6/3/2020 | Detector kit | <0.3 |
| Liberty Elementary | Liberty Elementary | First Floor Modular Room | 4155906 | 6/3/2020 | Detector kit | <0.3 |
| Liberty Elementary | Liberty Elementary | First Floor Room Kitchen | 4155908 | 6/3/2020 | Detector kit | <0.3 |
| Liberty Elementary | Liberty Elementary | Room Gym | 4156268 | 6/3/2020 | Detector kit | <0.3 |
| Liberty Elementary | Liberty Elementary | Room Gym | 4156269 | 6/3/2020 | Detector kit | <0.3 |
| Liberty Elementary | Liberty Elementary | Room Gym | 4155903 | 6/3/2020 | Detector kit | 0.4 |
| Liberty Elementary | Liberty Elementary | Room Gym Duplicate | 4155902 | 6/3/2020 | Duplicate | 0.4 |
| Liberty Elementary | Liberty Elementary | Room Office | 4156267 | 6/3/2020 | Detector kit | <0.3 |
| Liberty Elementary | Liberty Elementary | Classroom | 4155901 | 6/3/2020 | Detector kit | 0.4 |
| Tillamook High School | Tillamook High School | First Floor Room Front Office | 4155884 | 6/3/2020 | Detector kit | 0.7 |
| Tillamook High School | Tillamook High School | First Floor Room Front Office Duplicate | 4155883 | 6/3/2020 | Duplicate | 0.5 |
| Tillamook High School | Tillamook High School | First Floor Room Copy | 4155885 | 6/3/2020 | Detector kit | 0.6 |
| Tillamook High School | Tillamook High School | First Floor Room Attendance Office | 4155886 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook High School | Tillamook High School | First Floor Room Vice Principal | 4155887 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook High School | Tillamook High School | First Floor Room Principal Office | 4155888 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook High School | Tillamook High School | First Floor Room Career Center | 4155889 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook High School | Tillamook High School | First Floor Room Christopher Beema | 4155890 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook High School | Tillamook High School | First Floor Room Conference | 4156052 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook High School | Tillamook High School | First Floor Room Rex Metcalfe | 4156053 | 6/3/2020 | Detector kit | 0.6 |
| Tillamook High School | Tillamook High School | First Floor Room Elizabeth Shell | 4156054 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook High School | Tillamook High School | First Floor Room Counselor Office | 4156055 | 6/3/2020 | Detector kit | 0.5 |
| Tillamook High School | Tillamook High School | First Floor Room Resource Office | 4156056 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook High School | Tillamook High School | First Floor Room Cafeteria | 4156058 | 6/3/2020 | Detector kit | 0.7 |
| Tillamook High School | Tillamook High School | First Floor Room Cafeteria | 4156057 | 6/3/2020 | Detector kit | 0.4 |
| Tillamook High School | Tillamook High School | First Floor Room Cafeteria | 4156059 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook High School | Tillamook High School | First Floor Room Food Lab | 4156060 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook High School | Tillamook High School | First Floor Room Family Lab | 4156142 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook High School | Tillamook High School | First Floor Room Cafeteria Office | 4155947 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook High School | Tillamook High School | First Floor Room Business Office | 4155882 | 6/3/2020 | Detector kit | 0.5 |
| Tillamook High School | Tillamook High School | First Floor Room 4 | 4155948 | 6/3/2020 | Detector kit | 0.9 |
| Tillamook High School | Tillamook High School | First Floor Room 5 | 4155949 | 6/3/2020 | Detector kit | 0.6 |
| Tillamook High School | Tillamook High School | First Floor Room 5 Duplicate | 4155950 | 6/3/2020 | Duplicate | 0.6 |
| Tillamook High School | Tillamook High School | First Floor Room 6 | 4155946 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook High School | Tillamook High School | First Floor Room 7 | 4155974 | 6/3/2020 | Detector kit | 0.8 |
| Tillamook High School | Tillamook High School | First Floor Room 8 | 4155975 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook High School | Tillamook High School | First Floor Room 10 | 4155976 | 6/3/2020 | Detector kit | 0.7 |
| Tillamook High School | Tillamook High School | First Floor Room Visual Art Center | 4155977 | 6/3/2020 | Detector kit | 0.6 |
| Tillamook High School | Tillamook High School | First Floor Room 9 | 4155979 | 6/3/2020 | Detector kit | <0.3 |

Tillamook School District Radon Testing Results

The EPA's recommended action level for radon is 4 pCi/L and will require mitigation by the district, followed by retesting.

14 Spike tests were conducted to ensure the integrity of the testing process and all spike tests passed satisfactorily.

| Site Name | Building Name | Room Description (per floor plan) | Kit serial # | Date Sampled | Type of test | Results (pCi/L) |
|-----------------------|-----------------------|--------------------------------------|--------------|-----------------|--------------|--------------------|
| Tillamook High School | Tillamook High School | First Floor Room Library Comp | 4155980 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook High School | Tillamook High School | First Floor Room 13 | 4156082 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook High School | Tillamook High School | First Floor Room 13 Duplicate | 4156081 | 6/3/2020 | Duplicate | <0.3 |
| Tillamook High School | Tillamook High School | First Floor Room 14 | 4156083 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook High School | Tillamook High School | First Floor Room Library | 4156084 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook High School | Tillamook High School | First Floor Room Library | 4156085 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook High School | Tillamook High School | First Floor Room Library | 4156086 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook High School | Tillamook High School | First Floor Room Library | 4156087 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook High School | Tillamook High School | First Floor Room Circulation | 4156090 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook High School | Tillamook High School | First Floor Break Room Library | 4156089 | 6/3/2020 | Detector kit | 0.6 |
| Tillamook High School | Tillamook High School | First Floor Room Audio/Visual | 4156088 | 6/3/2020 | Detector kit | 0.7 |
| Tillamook High School | Tillamook High School | First Floor Room Audio/Visual | 4156101 | 6/3/2020 | Duplicate | 0.4 |
| Tillamook High School | Tillamook High School | First Floor Room Staff Lounge | 4156102 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook High School | Tillamook High School | First Floor Room 39 | 4156103 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook High School | Tillamook High School | First Floor Room 37 | 4156071 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook High School | Tillamook High School | First Floor Room 38 | 4156072 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook High School | Tillamook High School | First Floor Room 36 | 4156074 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook High School | Tillamook High School | First Floor Room 34 | 4156075 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook High School | Tillamook High School | First Floor Room 35 | 4156076 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook High School | Tillamook High School | First Floor Room Athletics | 4156077 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook High School | Tillamook High School | First Floor Room Athletics Office | 4156079 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook High School | Tillamook High School | First Floor Room 16 | 4156080 | 6/3/2020 | Detector kit | 0.4 |
| Tillamook High School | Tillamook High School | First Floor Room Staff Lounge | 4156104 | 6/3/2020 | Detector kit | 0.4 |
| Tillamook High School | Tillamook High School | First Floor Room 21 | 4156105 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook High School | Tillamook High School | First Floor Room Projects | 4156106 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook High School | Tillamook High School | First Floor Room Projects Dupli | 4156107 | 6/3/2020 | Duplicate | <0.3 |
| Tillamook High School | Tillamook High School | First Floor Room 22 | 4156108 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook High School | Tillamook High School | First Floor Room 17 | 4156109 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook High School | Tillamook High School | First Floor Room 18 | 4156110 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook High School | Tillamook High School | First Floor Room 20 | 4156132 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook High School | Tillamook High School | First Floor Room 19 | 4156133 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook High School | Tillamook High School | First Floor Room 23 | 4156134 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook High School | Tillamook High School | First Floor Room Gym 1 | 4156135 | 6/3/2020 | Detector kit | 1.5 |
| Tillamook High School | Tillamook High School | First Floor Room Gym 1 Duplica | 4156136 | 6/3/2020 | Duplicate | 0.9 |
| Tillamook High School | Tillamook High School | First Floor Room Gym 1 | 4156137 | 6/3/2020 | Detector kit | 1.6 |
| Tillamook High School | Tillamook High School | First Floor Room Gym 1 | 4156138 | 6/3/2020 | Detector kit | 1.2 |
| Tillamook High School | Tillamook High School | First Floor Room Gym 1 | 4156139 | 6/3/2020 | Detector kit | 0.8 |
| Tillamook High School | Tillamook High School | First Floor Room Gym 1 | 4156140 | 6/3/2020 | Detector kit | 0.9 |
| Tillamook High School | Tillamook High School | First Floor Room Gym 1 | 4156170 | 6/3/2020 | Detector kit | 0.9 |
| Tillamook High School | Tillamook High School | First Floor Room Girls Locker | 4156069 | 6/3/2020 | Detector kit | 0.8 |
| Tillamook High School | Tillamook High School | First Floor Room Girls Locker D | 4156070 | 6/3/2020 | Duplicate | 0.5 |
| Tillamook High School | Tillamook High School | First Floor Room Girls Sports Lc | 4156067 | 6/3/2020 | Detector kit | 0.4 |
| Tillamook High School | Tillamook High School | First Floor Room Girls Sports Lc | 4156068 | 6/3/2020 | Duplicate | 0.7 |
| Tillamook High School | Tillamook High School | First Floor Room Girls Sports Lc | 4156066 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook High School | Tillamook High School | First Floor Room 25 | 4156065 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook High School | Tillamook High School | First Floor Room 25 Office | 4156064 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook High School | Tillamook High School | First Floor Room 25 Addition | 4156063 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook High School | Tillamook High School | First Floor Room Boys Locker | 4156171 | 6/3/2020 | Detector kit | 0.5 |
| Tillamook High School | Tillamook High School | First Floor Room Boys Team Lo | 4156172 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook High School | Tillamook High School | First Floor Room Boys Team Lo | 4156174 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook High School | Tillamook High School | First Floor Room Weight | 4156175 | 6/3/2020 | Detector kit | 0.4 |
| Tillamook High School | Tillamook High School | First Floor Room Weight | 4156176 | 6/3/2020 | Detector kit | 0.6 |
| Tillamook High School | Tillamook High School | First Floor Room Weight | 4156177 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook High School | Tillamook High School | First Floor Room Athletic Traine | 4156178 | 6/3/2020 | Detector kit | 1.0 |
| Tillamook High School | Tillamook High School | First Floor Room Athletic Traine | 4156179 | 6/3/2020 | Detector kit | 0.7 |
| Tillamook High School | Tillamook High School | First Floor Room Gym 2 | 4156180 | 6/3/2020 | Detector kit | 0.5 |
| Tillamook High School | Tillamook High School | First Floor Room Gym 2 | 4156114 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook High School | Tillamook High School | First Floor Room Gym 2 Duplica | 4156115 | 6/3/2020 | Duplicate | <0.3 |
| Tillamook High School | Tillamook High School | First Floor Room Gym 2 | 4156112 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook High School | Tillamook High School | First Floor Room Gym 2 | 4156113 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook High School | Tillamook High School | First Floor Room Gym 2 | 4156111 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook High School | Tillamook High School | First Floor Room 28 | 4156116 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook High School | Tillamook High School | First Floor Room 30 | 4156117 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook High School | Tillamook High School | First Floor Room 30 Duplicate | 4156118 | 6/3/2020 | Duplicate | 0.5 |
| Tillamook High School | Tillamook High School | First Floor Room 31 | 4156119 | 6/3/2020 | Detector kit | 0.4 |
| Tillamook High School | Tillamook High School | First Floor Room 32 | 4156120 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook High School | Tillamook High School | First Floor Room 33 | 4156226 | 6/3/2020 | Detector kit | 0.4 |
| Tillamook High School | Tillamook High School | First Floor Room 29 | 4156225 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook High School | Tillamook High School | First Floor Room Mr Begins Coa | 4156228 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook High School | Tillamook High School | First Floor Room Girls Locker O | 4156224 | 6/3/2020 | Detector kit | 0.4 |

Tillamook School District Radon Testing Results

The EPA's recommended action level for radon is 4 pCi/L and will require mitigation by the district, followed by retesting. 14 Spike tests were conducted to ensure the integrity of the testing process and all spike tests passed satisfactorily.

| Site Name | Building Name | Room Description (per floor plan) | Kit serial # | Date Sampled | Type of test | Results (pCi/L) |
|--------------------------|--------------------------|--------------------------------------|--------------|--------------|--------------|--------------------|
| Tillamook High School | Tillamook High School | First Floor Room Referees Lock | 4156229 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook High School | Tillamook High School | First Floor Room Office | 4156230 | 6/3/2020 | Detector kit | 0.6 |
| Tillamook High School | Tillamook High School | First Floor Room Concessions | 4156223 | 6/3/2020 | Detector kit | 1.0 |
| Tillamook High School | Tillamook High School | First Floor Room Band Office | 4156221 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook High School | Tillamook High School | First Floor Room Band | 4156222 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook High School | Tillamook High School | First Floor Room Practice 1 | 4156061 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook High School | Tillamook High School | First Floor Room Practice 2 | 4156163 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook High School | Tillamook High School | First Floor Room Practice 3 | 4156062 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook High School | Tillamook High School | First Floor Room Chorus | 4156164 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook High School | Tillamook High School | First Floor Room Practice | 4156162 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook High School | Tillamook High School | First Floor Room Chorus Kitche | 4156161 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook High School | Tillamook High School | First Floor Room Chorus Office | 4156165 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook High School | Tillamook High School | First Floor Room Gym 1 | 4156282 | 11/20/2020 | Detector kit | 0.5 |
| Tillamook High School | Tillamook High School | First Floor Room Gym 2 | 4156283 | 11/20/2020 | Detector kit | 0.7 |
| Tillamook High School | Tillamook High School | First Floor Room Gym 3 | 4156289 | 11/20/2020 | Detector kit | 1.2 |
| Tillamook High School | Tillamook High School | First Floor Room Gym 4 | 4156281 | 11/20/2020 | Detector kit | 0.6 |
| Tillamook High School | Tillamook High School | First Floor Room Gym 4 | 4156286 | 11/20/2020 | Duplicate | 0.6 |
| Tillamook High School | Tillamook High School | First Floor Room Stage 1 | 4156285 | 11/20/2020 | Detector kit | 0.6 |
| Tillamook High School | Tillamook High School | First Floor Room Stage 2 | 4156284 | 11/20/2020 | Detector kit | 0.9 |
| Tillamook VoAg Building | Tillamook VoAg Building | First Floor Room 43 | 4156169 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook VoAg Building | Tillamook VoAg Building | First Floor Room 46 | 4156168 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook VoAg Building | Tillamook VoAg Building | First Floor Room 46 | 4156166 | 6/3/2020 | Detector kit | 0.4 |
| Tillamook VoAg Building | Tillamook VoAg Building | First Floor Room 45 | 4156167 | 6/3/2020 | Detector kit | 0.9 |
| Tillamook VoAg Building | Tillamook VoAg Building | First Floor Room 41 | 4156211 | 6/3/2020 | Detector kit | 0.4 |
| Tillamook VoAg Building | Tillamook VoAg Building | First Floor Room 41 | 4156212 | 6/3/2020 | Detector kit | 0.6 |
| Tillamook VoAg Building | Tillamook VoAg Building | First Floor Room 41 Classroom | 4156213 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook VoAg Building | Tillamook VoAg Building | First Floor Room 41 | 4156214 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook VoAg Building | Tillamook VoAg Building | First Floor Room 40 | 4156215 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook VoAg Building | Tillamook VoAg Building | First Floor Room 40 (Dup) | 4156216 | 6/3/2020 | Duplicate | <0.3 |
| Tillamook VoAg Building | Tillamook VoAg Building | First Floor Room Mechanics Office | 4156217 | 6/3/2020 | Detector kit | 0.5 |
| Tillamook VoAg Building | Tillamook VoAg Building | First Floor Room 40 | 4156218 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook VoAg Building | Tillamook VoAg Building | First Floor Classroom 40 | 4156219 | 6/3/2020 | Detector kit | <0.3 |
| South Prairie Elementary | South Prairie Elementary | First Floor Room Library | 4156220 | 6/3/2020 | Detector kit | <0.3 |
| South Prairie Elementary | South Prairie Elementary | First Floor Room Library | 4156274 | 6/3/2020 | Detector kit | 0.8 |
| South Prairie Elementary | South Prairie Elementary | First Floor Room Library | 4156272 | 6/3/2020 | Detector kit | 0.9 |
| South Prairie Elementary | South Prairie Elementary | First Floor Room Library | 4156273 | 6/3/2020 | Detector kit | <0.3 |
| South Prairie Elementary | South Prairie Elementary | First Floor Room Health | 4156276 | 6/3/2020 | Detector kit | <0.3 |
| South Prairie Elementary | South Prairie Elementary | First Floor Room Principal | 4156275 | 6/3/2020 | Detector kit | 0.4 |
| South Prairie Elementary | South Prairie Elementary | First Floor Room Mrs Woolfolk | 4156277 | 6/3/2020 | Detector kit | 0.6 |
| South Prairie Elementary | South Prairie Elementary | First Floor Room Kitchen Office | 4156278 | 6/3/2020 | Detector kit | 1.0 |
| South Prairie Elementary | South Prairie Elementary | First Floor Workroom | 4156279 | 6/3/2020 | Detector kit | 0.4 |
| South Prairie Elementary | South Prairie Elementary | First Floor Room Cafeteria | 4156280 | 6/3/2020 | Detector kit | <0.3 |
| South Prairie Elementary | South Prairie Elementary | First Floor Room Gym | 4156207 | 6/3/2020 | Detector kit | <0.3 |
| South Prairie Elementary | South Prairie Elementary | First Floor Room Gym | 4156208 | 6/3/2020 | Detector kit | <0.3 |
| South Prairie Elementary | South Prairie Elementary | First Floor Room Gym | 4156209 | 6/3/2020 | Detector kit | <0.3 |
| South Prairie Elementary | South Prairie Elementary | First Floor Room Gym Duplicate | 4156210 | 6/3/2020 | Duplicate | <0.3 |
| South Prairie Elementary | South Prairie Elementary | First Floor Room Gym Office | 4156206 | 6/3/2020 | Detector kit | 1.0 |
| South Prairie Elementary | South Prairie Elementary | First Floor Room Teachers Lour | 4156205 | 6/3/2020 | Detector kit | <0.3 |
| South Prairie Elementary | South Prairie Elementary | First Floor Room 124 | 4156203 | 6/3/2020 | Detector kit | 0.6 |
| South Prairie Elementary | South Prairie Elementary | First Floor Room 125 | 4156202 | 6/3/2020 | Detector kit | 0.5 |
| South Prairie Elementary | South Prairie Elementary | First Floor Room 150 | 4156204 | 6/3/2020 | Detector kit | <0.3 |
| South Prairie Elementary | South Prairie Elementary | First Floor Room 126 | 4156241 | 6/3/2020 | Detector kit | 0.8 |
| South Prairie Elementary | South Prairie Elementary | First Floor Room 126 Duplicate | 4156201 | 6/3/2020 | Duplicate | 0.4 |
| South Prairie Elementary | South Prairie Elementary | First Floor Room 123 | 4156242 | 6/3/2020 | Detector kit | <0.3 |
| South Prairie Elementary | South Prairie Elementary | First Floor Room 121 | 4156243 | 6/3/2020 | Detector kit | 0.6 |
| South Prairie Elementary | South Prairie Elementary | First Floor Room 122 | 4156244 | 6/3/2020 | Detector kit | <0.3 |
| South Prairie Elementary | South Prairie Elementary | First Floor Room Speech | 4156245 | 6/3/2020 | Detector kit | 0.4 |
| South Prairie Elementary | South Prairie Elementary | First Floor Room 114 | 4156246 | 6/3/2020 | Detector kit | 0.4 |
| South Prairie Elementary | South Prairie Elementary | First Floor Room 115 | 4156247 | 6/3/2020 | Detector kit | 0.8 |
| South Prairie Elementary | South Prairie Elementary | First Floor Room 112 | 4156248 | 6/3/2020 | Detector kit | 0.6 |
| South Prairie Elementary | South Prairie Elementary | First Floor Room 112 Duplicate | 4156249 | 6/3/2020 | Duplicate | 0.5 |
| South Prairie Elementary | South Prairie Elementary | First Floor Room 111 | 4156250 | 6/3/2020 | Detector kit | <0.3 |
| South Prairie Elementary | South Prairie Elementary | First Floor Room 110 | 4156231 | 6/3/2020 | Detector kit | 0.5 |
| South Prairie Elementary | South Prairie Elementary | First Floor Room 106 | 4156232 | 6/3/2020 | Detector kit | 0.7 |
| South Prairie Elementary | South Prairie Elementary | First Floor Room 116 | 4156233 | 6/3/2020 | Detector kit | 0.6 |
| South Prairie Elementary | South Prairie Elementary | First Floor Room 103 | 4156234 | 6/3/2020 | Detector kit | 0.4 |
| South Prairie Elementary | South Prairie Elementary | First Floor Room 104 | 4156235 | 6/3/2020 | Detector kit | <0.3 |
| South Prairie Elementary | South Prairie Elementary | First Floor Room 105 | 4156236 | 6/3/2020 | Detector kit | <0.3 |
| South Prairie Elementary | South Prairie Elementary | First Floor Room 108 | 4156238 | 6/3/2020 | Detector kit | 0.7 |
| South Prairie Elementary | South Prairie Elementary | First Floor Room 109 | 4156239 | 6/3/2020 | Detector kit | 0.5 |

Tillamook School District Radon Testing Results

The EPA's recommended action level for radon is 4 pCi/L and will require mitigation by the district, followed by retesting.
14 Spike tests were conducted to ensure the integrity of the testing process and all spike tests passed satisfactorily.

| Site Name | Building Name | Room Description (per floor plan) | Kit serial # | Date Sampled | Type of test | Results (pCi/L) |
|-----------------------|-----------------------|--------------------------------------|--------------|--------------|--------------|--------------------|
| Tillamook Junior High | Tillamook Junior High | First Floor Room 1 | 4156122 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook Junior High | Tillamook Junior High | First Floor Room 1 Workroom | 4155945 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook Junior High | Tillamook Junior High | First Floor Room 2 Workroom | 4156123 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook Junior High | Tillamook Junior High | First Floor Room 2 | 4156125 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook Junior High | Tillamook Junior High | First Floor 2 Backroom | 4155940 | 6/3/2020 | Detector kit | 0.4 |
| Tillamook Junior High | Tillamook Junior High | First Floor 3 Breakroom | 4155962 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook Junior High | Tillamook Junior High | First Floor Room 3 | 4155963 | 6/3/2020 | Detector kit | 0.4 |
| Tillamook Junior High | Tillamook Junior High | First Floor Room 4 | 4155932 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook Junior High | Tillamook Junior High | First Floor Room 5 | 4155961 | 6/3/2020 | Detector kit | 0.4 |
| Tillamook Junior High | Tillamook Junior High | First Floor Room 6 | 4156127 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook Junior High | Tillamook Junior High | First Floor Room 7 | 4156129 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook Junior High | Tillamook Junior High | First Floor Room 7 Duplicate | 4156130 | 6/3/2020 | Duplicate | <0.3 |
| Tillamook Junior High | Tillamook Junior High | First Floor Room 8 | 4156128 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook Junior High | Tillamook Junior High | First Floor Room Library Back | 4155964 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook Junior High | Tillamook Junior High | First Floor Room Library Office | 4155965 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook Junior High | Tillamook Junior High | First Floor Room Library | 4155967 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook Junior High | Tillamook Junior High | First Floor Room Library Duplic | 4155966 | 6/3/2020 | Duplicate | <0.3 |
| Tillamook Junior High | Tillamook Junior High | First Floor Room Computer | 4155969 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook Junior High | Tillamook Junior High | First Floor Room Work | 4155968 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook Junior High | Tillamook Junior High | Behind Computer Room | 4155970 | 6/3/2020 | Detector kit | 0.7 |
| Tillamook Junior High | Tillamook Junior High | Room 16 | 4155989 | 6/3/2020 | Detector kit | 0.8 |
| Tillamook Junior High | Tillamook Junior High | Room 16 Duplicate | 4155990 | 6/3/2020 | Duplicate | 0.6 |
| Tillamook Junior High | Tillamook Junior High | Room 15 | 4155943 | 6/3/2020 | Detector kit | 0.5 |
| Tillamook Junior High | Tillamook Junior High | Room 9 | 4155988 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook Junior High | Tillamook Junior High | Room 10 | 4156148 | 6/3/2020 | Detector kit | 0.6 |
| Tillamook Junior High | Tillamook Junior High | Room 11 | 4156126 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook Junior High | Tillamook Junior High | Room 14 | 4155944 | 6/3/2020 | Detector kit | 0.4 |
| Tillamook Junior High | Tillamook Junior High | Room 12 | 4156255 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook Junior High | Tillamook Junior High | First Floor Room 13 | 4155987 | 6/3/2020 | Detector kit | 0.5 |
| Tillamook Junior High | Tillamook Junior High | First Floor Room 17 | 4155985 | 6/3/2020 | Detector kit | 0.5 |
| Tillamook Junior High | Tillamook Junior High | First Floor Resource Room | 4155986 | 6/3/2020 | Detector kit | 0.9 |
| Tillamook Junior High | Tillamook Junior High | First Floor Room Gym | 4156093 | 6/3/2020 | Detector kit | 0.5 |
| Tillamook Junior High | Tillamook Junior High | First Floor Room Gym Duplicate | 4156094 | 6/3/2020 | Duplicate | 0.4 |
| Tillamook Junior High | Tillamook Junior High | Room Gym | 4156092 | 6/3/2020 | Detector kit | 0.9 |
| Tillamook Junior High | Tillamook Junior High | Room Gym | 4155983 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook Junior High | Tillamook Junior High | Room Gym | 4155982 | 6/3/2020 | Detector kit | 0.5 |
| Tillamook Junior High | Tillamook Junior High | First Floor Women's Locker Ro | 4155984 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook Junior High | Tillamook Junior High | First Floor Men's Locker Room | 4156124 | 6/3/2020 | Detector kit | 0.7 |
| Tillamook Junior High | Tillamook Junior High | First Floor Room Computer | 4156096 | 6/3/2020 | Detector kit | 0.7 |
| Tillamook Junior High | Tillamook Junior High | First Floor Room Shop | 4156099 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook Junior High | Tillamook Junior High | First Floor Room Shop Extensio | 4156098 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook Junior High | Tillamook Junior High | First Floor Shop Small Room | 4156097 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook Junior High | Tillamook Junior High | First Floor Room Arts & Crafts | 4155850 | 6/3/2020 | Detector kit | 0.5 |
| Tillamook Junior High | Tillamook Junior High | First Floor Room Arts & Crafts P | 4155849 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook Junior High | Tillamook Junior High | First Floor Room Mechanical | 4155848 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook Junior High | Tillamook Junior High | First Floor Room Lesson | 4155845 | 6/3/2020 | Detector kit | 0.4 |
| Tillamook Junior High | Tillamook Junior High | First Floor Room Lesson | 4155846 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook Junior High | Tillamook Junior High | First Floor Room Office | 4155844 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook Junior High | Tillamook Junior High | First Floor Room Office | 4155843 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook Junior High | Tillamook Junior High | First Floor Room Music | 4155847 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook Junior High | Tillamook Junior High | First Floor Room Music | 4156100 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook Junior High | Tillamook Junior High | First Floor Room Music Duplica | 4155900 | 6/3/2020 | Duplicate | <0.3 |
| Tillamook Junior High | Tillamook Junior High | First Floor Room Stage | 4155899 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook Junior High | Tillamook Junior High | First Floor Room Cafeteria | 4155897 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook Junior High | Tillamook Junior High | First Floor Room Cafeteria Dup | 4155898 | 6/3/2020 | Duplicate | <0.3 |
| Tillamook Junior High | Tillamook Junior High | First Floor Room Cafeteria | 4155896 | 6/3/2020 | Detector kit | <0.3 |
| Tillamook Junior High | Tillamook Junior High | First Floor Room Health | 4155895 | 6/3/2020 | Detector kit | 0.5 |
| Tillamook Junior High | Tillamook Junior High | First Floor Room Counselors Of | 4155894 | 6/3/2020 | Detector kit | 0.5 |
| Tillamook Junior High | Tillamook Junior High | Room Staff Lounge | 4155893 | 6/3/2020 | Detector kit | 0.4 |
| Tillamook Junior High | Tillamook Junior High | Room Dean of Students | 4155892 | 6/3/2020 | Detector kit | 0.9 |
| Tillamook Junior High | Tillamook Junior High | Room Resource Office | 4155891 | 6/3/2020 | Detector kit | 0.6 |
| Tillamook Junior High | Tillamook Junior High | Room Principal | 4156095 | 6/3/2020 | Detector kit | 1.0 |
| Tillamook Junior High | Tillamook Junior High | Room In School Detention | 4155920 | 6/3/2020 | Detector kit | 0.7 |
| Tillamook Junior High | Tillamook Junior High | Room Waiting | 4155917 | 6/3/2020 | Detector kit | 0.4 |
| Tillamook Junior High | Tillamook Junior High | Room Office | 4155918 | 6/3/2020 | Detector kit | 0.5 |
| Tillamook Junior High | Tillamook Junior High | Room Office | 4155919 | 6/3/2020 | Detector kit | <0.3 |
| District Office | District Office | First Floor Room Finance Office | 4156349 | 6/3/2020 | Detector kit | 1.1 |
| District Office | District Office | First Floor Room Accounting Of | 4156350 | 6/3/2020 | Detector kit | 1.0 |
| District Office | District Office | First Floor Room Payroll | 4156348 | 6/3/2020 | Detector kit | 1.0 |
| District Office | District Office | First Floor Room Clerks Office | 4156345 | 6/3/2020 | Detector kit | 2.4 |

Tillamook School District Radon Testing Results

The EPA's recommended action level for radon is 4 pCi/L and will require mitigation by the district, followed by retesting. 14 Spike tests were conducted to ensure the integrity of the testing process and all spike tests passed satisfactorily.

| Site Name | Building Name | Room Description (per floor plan) | Kit serial # | Date Sampled | Type of test | Results (pCi/L) |
|-----------------|-----------------|--------------------------------------|--------------|--------------|--------------|--------------------|
| District Office | District Office | First Floor Room Special Educa | 4156346 | 6/3/2020 | Detector kit | 1.1 |
| District Office | District Office | First Floor Room Miami Confer | 4156344 | 6/3/2020 | Detector kit | 1.3 |
| District Office | District Office | First Floor Room Secretary Sup | 4156343 | 6/3/2020 | Detector kit | 0.9 |
| District Office | District Office | First Floor Room Superintende | 4156341 | 6/3/2020 | Detector kit | 0.7 |
| District Office | District Office | First Floor Room Superintende | 4156342 | 6/3/2020 | Duplicate | 0.6 |
| District Office | District Office | First Floor Coordinator Office | 4156347 | 6/3/2020 | Detector kit | 2.0 |
| District Office | District Office | First Floor Room Grant Writer | 4156310 | 6/3/2020 | Detector kit | 1.2 |
| District Office | District Office | First Floor OTL | 4156309 | 6/3/2020 | Detector kit | 1.3 |
| District Office | District Office | First Floor OTL Field Blank | 4156308 | 6/3/2020 | Detector kit | <0.3 |
| District Office | District Office | First Floor Room Finance Office | 4156307 | 6/3/2020 | Detector kit | 0.7 |
| District Office | District Office | First Floor Room Reception | 4156306 | 6/3/2020 | Detector kit | 0.6 |
| District Office | District Office | First Floor Room Mail/Copy | 4156305 | 6/3/2020 | Detector kit | 1.4 |
| District Office | District Office | First Floor Room Conference | 4156304 | 6/3/2020 | Detector kit | 0.9 |
| District Office | District Office | First Floor Room Conference D | 4156303 | 6/3/2020 | Duplicate | 1.0 |
| District Office | District Office | First Floor Room Task Conf. | 4156302 | 6/3/2020 | Detector kit | <0.3 |
| District Office | District Office | First Floor Room Kilchis Conf. | 4156301 | 6/3/2020 | Detector kit | 1.2 |
| District Office | District Office | First Floor Room Break | 4156292 | 6/3/2020 | Detector kit | 0.8 |
| Retakes: | | | | | | |
| District Office | District Office | Clerk's Office | 4155909 | 7/24/2020 | Detector kit | 2.5 |
| District Office | District Office | Clerk's Office Duplicate | 4155910 | 7/24/2020 | Detector kit | 2.8 |
| District Office | District Office | Coordinator's Office | 4156266 | 7/24/2020 | Detector kit | 3.9 |
| | | | | | | |